



OFFICE OF THE DEPUTY FIRE OFFICER,
CUTTACK CIRCLE, CUTTACK

FORM-V
FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules,2017)

File No-X-2-B-18-2023

Certificate No- 87 /CR.CTC

Dt-19-02-2023

This Certificate is valid up to 18-02-2025(Midnight)

(Apply for renewal at least three months before expiry)

With reference to your Online Fire Safety Application No FSC1101040012020000038, you have applied for issuance of Fire Safety Certificate in respect of G+1 storied Residential Building in the name of "DPIS Utkal", situated over Plot No. 560, 560/806, Khata No. 232/314, Mouza - Goudapatna, Tahasil- Aul, Dist.- Kendrapara. was inspected by officers of Odisha Fire Service on 16-12-2022 and re- inspected on 16-01-2023 in the presence of the Chairman and Principal of "DPIS Utkal", and it has been found to Comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety (Amendment) Rules 2019 and one time relaxation scheme vide Home Department Notification No- 28423/CD BBSR dtd- 20-08-2020. Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

G-Floor	---usage---	Reception, Principal Office, Staff Common Room, Class Rooms
1 st -Floor	---usage---	Class Rooms, Library, Computer Lab, Science Lab

CONDITIONS:-

1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access there to etc provided in the building or premises, should be maintained by the occupier (S) in best repairs and efficient working condition at all times for use by the members of the Fire Service or both in the event of outbreak of fire. Occupants or the
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (S) shall train all staff and occupants periodically to make them well conversant in use and operation of fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving Local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous Places in all lobbies/corridors in all floors of all tower/blocks of building/premises.

By order of the Director of fire Service

Sd/-

DPIS Utkal

Aulha

Principal

(Trilok Kumar Babu)

Deputy Fire Officer

Cuttack Circle, Cuttack

19-02-23
Deputy Fire Officer
Cuttack Circle, Cuttack